

Thermoline Ltd.

47 Tzela Hahar st., Modiin, Israel Tel: 02-679-94-79

Tel: 03-550-45-27

www.thermoline.co.il/control

XJRS485

Opto-insulated serial interface D: 4 DIN Rail mounting



The XJRS485 opto-insulated serial interface converts the TTL output into a RS485 signal that can be used to connect the controller via an RS485 network to the controlling and supervising system.